

ORDINANCE NO.: 2015-06

AN ORDINANCE TO AMEND THE SIGNAL MOUNTAIN MUNICIPAL CODE, TITLE 18, SECTION 18-116(2) ENTITLED "WATER SERVICE LINE MATERIAL" BY DELETING SECTION 18-116(2) IN ITS ENTIRETY AND SUBSTITUTING A NEW SECTION 18-116(2).

SECTION 1. BE IT ORDAINED BY THE TOWN COUNCIL OF THE TOWN OF SIGNAL MOUNTAIN, TENNESSEE, that Title 18 of the Signal Mountain Municipal Code is amended to delete Section 18-116(2) in its entirety and to substitute a new Section 18-116(2) in lieu thereof entitled "Water service line material" as follows:

18-116.

(2) Water service line material. All water service line material shall be either type "L" or "K" copper pipe or Blue PEX (Grade "A" polyethylene with ultraviolet protection) with brass fittings. PEX service lines should be installed with a "tracer wire" to facilitate future water line location/detection. All service line must be no smaller than three quarter inch (3/4") in size, must be installed at a minimum depth of twenty four (24) inches and must be covered with clean soil or other suitable material.


SECTION 2. That this Ordinance shall become effective immediately from and after its passage as provided by law.

Passed First Reading: August 28, 2015.

Passed Second Reading: September 14, 2015.



Dick Gee, Mayor



Recorder